

**Sophie MOURLON**

ASN - France

# Control & supervision of safety of nuclear pressure equipment

--

## Position of the French ASN

**Sophie MOURLON**

Head of sub-directorate “Nuclear pressure equipment” (BCCN)


# Ageing issues for nuclear pressure equipment

- **Degradation of mechanical properties of materials:** thermal ageing, irradiation embrittlement...
- **Degradation of equipment:** stress corrosion, fatigue...
- **Loss of skills and know-how:** engineering teams of utilities, manufacturers, sub-contractors...

**=> challenge for safe operating lifetime**

# The French reactors

- **58 PWR reactors**
- **all similar in design (Framatome)**
  - oldest: Fessenheim (1969)
  - most recent: Civaux (1996)
- **Advantages:**
  - feedback experience
- **Drawbacks:**
  - problems affect all reactors
  - ... at the same time



# Regulatory approach to ageing management (1)

- No licensing lifetime
- Operator responsible for the safety of the plant
  - surveillance in operation
  - in-service inspection
  - repairs, replacements
  - safety demonstration
- ASN may:
  - require comprehensive review of safety
  - stop a reactor if safety is challenged

# Regulatory approach to ageing management (2)

## ■ Periodic safety review (PSR)

- every 10 years
- check that safety requirements are still met → *maintain safety*
- implement technical improvements on equipment & operation → *improve safety*
- program defined by the utility, approved by ASN

## Regulatory approach to ageing management (3) **Nuclear pressure equipment**

- **Order of November 10<sup>th</sup>, 1999 for main primary system (MPS) and main secondary systems (MSS)**
- **Defence-in-depth approach:**
  - design
  - surveillance in operation
  - maintenance
  - feedback experience

# Design & fabrication

- Materials and their fabrication
- End-of-life mechanical properties
- Prevent fatigue
- Favour in-service inspection
- RCC-M code, « Technical rules for construction »



# Operation (1)

## ■ Surveillance

- monitor relevant parameters (P, T, chemistry,...)
- transient book keeping

*check that operating conditions are consistent with design hypothesis*

## ■ In-service inspection

- detect degradations and flaws...
- ...before they challenge integrity...
- ...and before they lead to a leak.

*check that materials behave as anticipated*

## Operation (2)

### ■ Ageing surveillance programmes

- for each degradation mode
- approved by ASN

### ■ In-service inspection

- analysis of expected degradations
- adaptation of NDE to flaws - performance demonstration
- definition of frequency
- sample checks
- feedback experience

## Operation (3)

### ■ Nature is more imaginative than engineers

- → sample checks
- → hydraulic test every 10 years
- e.g. Bugey 3 RPV head

- importance of national / international experience

### ■ Influence of operation procedures

# Maintenance

- **Availability of repair techniques and repair equipment**
  - technical skills
  - availability of sub-contractors
  - industrial capacity
- **Repair cracks when detected**
- **Research on replaced elements**

## Regulatory approach to ageing management Position of ASN

- The ASN considers that operation for 30 years is possible
- Beyond, a thorough analysis is required:
  - condition of the plant / ageing phenomena
  - demonstration that operation may proceed safely for 10 more years
- The utility submits « operation continuation aptitude cases » (DAPE)

# Conclusion

## ■ Ageing management

- good design
- thorough surveillance & in-service inspection
- repair & replace

## ■ Anticipate

- experience feedback
- sample checks, hydraulic test
- research, international experience